

**CITY of  
SPRINGFIELD**



March 14, 1994

Ms. Shirley Campbell  
c/o Carol Jones Realtors  
3600 S. National  
Springfield, MO 65807

RE: 2953 W. Mt. Vernon

Dear Ms. Campbell:

Personnel from this office dyed the building sewer line at the above address to determine whether it was connected to the City sewer system. After placing dye in the private sewer line and flushing with an adequate amount of water and waiting a sufficient amount of time, it appears that the private line is connected to the City's sanitary sewer system.

If we may be of further assistance, please do not hesitate to call 864-1923.

Yours truly,

*David Renkoski*

David Renkoski  
Water Pollution Control Inspector  
Surveillance & Enforcement

DR/jb

*2953 W. Mt. Vernon*